#### DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES Office of Structural Materials

Quality Assurance and Source Inspection

Bay Area Branch 690 Walnut Ave.St. 150 Vallejo, CA 94592-1133 (707) 649-5453 (707) 649-5493



Contract #: 04-0120F4

Cty: SF/ALA Rte: 80 PM: 13.2/13.9

File #: 69.28

# WELDING INSPECTION REPORT

Resident Engineer: Siegenthaler, Peter **Report No:** WIR-024172 Address: 333 Burma Road **Date Inspected:** 24-May-2011

City: Oakland, CA 94607

**OSM Arrival Time:** 700 **Project Name:** SAS Superstructure **OSM Departure Time:** 1900 **Prime Contractor:** American Bridge/Fluor Enterprises, a JV

Contractor: Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China

**CWI Name:** Liu Hua Jie/Lv Li Oing **CWI Present:** Yes No **Inspected CWI report:** Yes No **Rod Oven in Use:** Yes No N/A N/A Yes N/A N/A **Electrode to specification:** No Weld Procedures Followed: Yes No N/A N/A **Qualified Welders:** Yes No **Verified Joint Fit-up:** Yes No N/A Yes N/A **Approved Drawings:** Yes No **Approved WPS:** No **Delayed / Cancelled:** Yes No N/A

34-0006 **Bridge No: Component:** OBG

## **Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance (QA) Inspector, Nagalingam Pandaram Pillai was present during the times noted above for observations relative to the work being performed.

Ultrasonic Testing:-

**OBG** Trial Assembly

This QA Inspector performed Ultrasonic testing (UT) of approximately 10% of the area previously tested and accepted by ZPMC Quality control personnel. This QA inspector generated a (UT) report for this date. The members are identified as 13BE and 13CE Vertical Panel Stiffeners. The weld designation reviewed is as follows:

SEG3009F-224,225

VP3005-001-001,005,006,007,008

VP3006-001-001

VP3007-001-010,022,035,048,061,074

VP3008-001-013

OBE13K-001,002,003,004,005,006,007

In process Inspection:-

**OBG** Trial Assembly

# WELDING INSPECTION REPORT

(Continued Page 2 of 3)

This QA inspector observed the following work in progress:

SMAW welding of weld joint No: OBE13-002 located on OBG Segment 13AE and 13BE Deck panel Splice. Welder is identified as #068764. ZPMC QC is identified as Mr. Wang Li Yang. Welding was performed with the weld repair report BWR-21059. The welding variables recorded by QC appeared to comply with the WPS-345-SMAW-4G(4F)-FCM-Repair-1.

This QA inspector observed the following work in progress:

SMAW welding of weld joint No: SEG3011E-259 located on OBG Segment 13BE Architectural Housing Assembly. Welder is identified as #051359.ZPMC CWI is identified as Mr. Lv Li Qing. Welding was performed with the weld repair report BWR-21063. The welding variables recorded by QC appeared to comply with the WPS-345-SMAW-3G(3F)-FCM-Repair-1.

This QA Inspector observed the following work in progress:

SMAW in the 4G position for the OBG Segment 13CE Floor Beam Stiffener. The weld joint was designated as: SEG3011L-239. The welder is identified as #067183. ZPMC CWI is identified as Mr. Lv Li Qing. The welding variables recorded by QC appear to comply with WPS-B-P-2214-B-U2-FCM-1.

This QA Inspector observed the following work in progress:

FCAW in the 1G position for the OBG Segment 14E Vertical Panel Stiffener. The weld joint was designated as: VP3016-001-001. The welder is identified as #066041. ZPMC QC is identified as Mr. Wang Li Yang. The welding variables recorded by QC appear to comply with WPS-B-T-2231-ESAB. Please see the attached picture.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.





#### **Summary of Conversations:**

# WELDING INSPECTION REPORT

(Continued Page 3 of 3)

No Relevant Conversation.

### **Comments**

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 150-0042-2372, who represents the Office of Structural Materials for your project.

Inspected By:	Pillai,Pandaram	Quality Assurance Inspector
Reviewed By:	Patel, Hiranch	QA Reviewer